

FIG. 1

20221018965001




FIG. 2

20221018965001




FIG 3A




FIG 3B




FIG 3C







FIG. 4





2022108965001



20221089625001




FIG. 8



20221018955001





FIG. 9A

FIG. 9

PRIOR ART

202210 896E5001




FIG. 10

PRIOR ART

202210" 896E500T  
10053968 04220

Response Time from ambient to 90° F at 60 WSI




FIG. 11

202210-296E5001




FIG. 12




FIG. 13




FIG. 14

202210189625001




FIG. 15



FIG. 16

PRIOR ART

### Thermal Properties of Air @ Various Temperatures & 500 psig

Temperature, F	68	216	500	1000
Specific Heat Capacity, $C_p$	.241	.243	.250	.264
Thermal Conductivity, K	.0134	.0143	.0157	.0180
Viscosity, Absolute, $\mu$	.0442	.0540	.0715	.0977
Density, $\rho$	2.62	2.06	1.43	0.94

$C_p$  = BTU/lb-°F

K = BTU/Ft - hr - °F

$\mu$  = lb/Ft - hr

$\rho$  = lb/Ft<sup>3</sup>

FIG. 17

2025.08.01 10:53:56